



Glenn Grieb
Plant Manager
Vivendi Water North America

KIN-BUC LANDFILL
383 MEADOW RD.
EDISON, NJ 08837

TELEPHONE (732) 572-4743
FACSIMILE (732) 572-6294

February 22, 2002

Ms. Grisell V. Diaz-Cotto
Emergency and Remedial Response Division
United States Environmental Protection Agency
Region III
290 Broadway, 19th Floor
New York, NY 10007-1866

Re: January 2002 Discharge Monitoring Report
Leachate Treatment Plant, Operable Unit 1
Kin-Buc Landfill Superfund Site

Dear Ms. Diaz-Cotto:

The January 2002 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit 1, Kin-Buc Landfill Superfund Site, prepared by U.S. Filter Operating Services is attached. We will provide copies of the DMR to Ian Curtis and Susan Dietrick at the NJDEP.

Should you have any questions concerning the DMR or other site items, please contact me at your earliest convenience at the Kin-Buc site.

Very truly yours,
USFilter Operating Services
On behalf of SCA Services, Inc.,

Glenn Grieb
Plant Manager

Enclosure

cc: Ian Curtis – NJDEP
Susan Dietrick – NJDEP
Stephen Joyce – SCA
Carl Januszkiewicz – Waste Management
Richard Hoyt - USFilter

562186



NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.
*
*NJ Permit Equivalent

REPORTING PERIOD
M o. Y r. M o. Y r.

PERMITTEE: Name: SCA Services, Inc.
Address: 383 Meadow Road
Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill
Address: 383 Meadow Road
Edison, New Jersey 08817
Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY
__ T-VWX-007 __ T-VWX-008 __ T-VWX-009
__ EPA Form 3320-1

SLUDGE REPORT-INDUSTRIAL
__ T-VWX-010A __ T-VWX-010B

WASTEWATER REPORTS
__ T-VWX-011 __ T-VWX-012 __ T-VWX-013

GROUNDWATER REPORTS
__ T-VWX-015(A,B) __ T-VWX-016 __ T-VWX-017
__ ELECTRONIC SUBMISSION

	YES	NO
DYE TESTING	__	<u>X</u>
TEMPORARY BYPASSING	__	<u>X</u>
DISINFECTION INTERRUPTION	__	<u>X</u>
MONITORING MALFUNCTIONS	__	<u>X</u>
UNITS OF OPERATION	__	<u>X</u>
OTHER	__	<u>X</u>

NPDES DISCHARGE MONITORING
1 EPA Form 3320-1

(Detail any "Yes" on reverse side in appropriate space.)
NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER OR
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Glenn Grieb
Grade & Registry No. N-4; 001212
Signature *Glenn Grieb*

Name (Printed) Glenn Grieb
Title (Printed) Plant Operations Manager
Signature *Glenn Grieb*

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD
YEAR MO DAY YEAR MO DAY
02 01 01 02 01 31

FACILITY
LOCATION

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.030192	0.035240	MGD	*****	*****	*****	***	0	continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT			***	6.50		8.25	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	8.0			weekly	grab
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT			***	*****	<0.5	<0.5	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15			2/month	grab
COD	SAMPLE MEASUREMENT	21.7	30.5	kg/day	*****	251	261	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD	SAMPLE MEASUREMENT			***		<2.00	<2.00	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	*****	*****			*****	*****			2/month	comp.
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	<0.0846	<0.1263	kg/day	*****	<1.0	<1.0	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)			weekly	comp.
DISSOLVED OXYGEN	SAMPLE MEASUREMENT			***	10.0		11.2	mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN Instantaneous	*****	*****			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE	
Glenn Grieb Project Manager								732 572-4743		02 02 21	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR MO DAY	

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

**SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817**

FACILITY
LOCATION
ATTN:

**KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
02	01	01	02	01	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BENZENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.009	0.02		*****	57	134			2/month	grab
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.005	0.009		*****	22	58			2/month	grab
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.008	0.025		*****	52	154			2/month	grab
TOLUENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.009		*****	25	80			2/month	grab

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

Glenn Grieb
Project Manager

TYPED OR PRINTED

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)

Glenn Grieb
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

732 572-4743

AREA NUMBER

DATE

02 02 21

YEAR MO DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME **SCA SERVICES, INC.**
 ADDRESS **383 MEADOW ROAD**
EDISON, NEW JERSEY 08817

FACILITY **KIN-BUC LANDFILL**
 LOCATION **EDISON, NEW JERSEY**
 ATTN: **CARL JANUSZKIEWICZ**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
 DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
02	01	01		02	01	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00027	<0.00029	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab	
	PERMIT REQUIREMENT	0.004	0.010		*****	26	69			2/month	grab	
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.00027	<0.00031	kg/day	*****	<2.5	<2.5	ug/L	0	1/week	grab	
	PERMIT REQUIREMENT	0.008	0.018		*****	52.8	106			weekly	grab	
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.00010	<0.00010	kg/day	*****	<0.91	<0.92	ug/L	0	1/month	grab	
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab	
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.000095	<0.000099	kg/day	*****	<0.86	<0.87	ug/L	0	1/month	grab	
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab	
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.000051	<0.000053	kg/day	*****	<0.47	<0.47	ug/L	0	1/month	grab	
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab	
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.000057	<0.000059	kg/day	*****	<0.52	<0.53	ug/L	0	1/month	grab	
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab	
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.000098	<0.000101	kg/day	*****	<0.89	<0.90	ug/L	0	1/month	grab	
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE		
Glenn Grieb Project Manager								732 572-4743		02 02 21		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME **SCA SERVICES, INC.**
 ADDRESS **383 MEADOW ROAD**
EDISON, NEW JERSEY 08817

FACILITY **KIN-BUC LANDFILL**
 LOCATION **EDISON, NEW JERSEY**
 ATTN: **CARL JANUSZKIEWICZ**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
 DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT		001	
PERMIT NUMBER		DISCHARGE NUMBER	
MONITORING PERIOD			
YEAR	MO	DAY	TO
02	01	01	02 01 31

PARAMETER		QUANTITY OR LOAD			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.000063	<0.000065	kg/day	*****	<0.57	<0.58	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
PHENANTHRENE	SAMPLE MEASUREMENT	<0.000059	<0.000069	kg/day	*****	<0.55	<0.57	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab
ALDRIN	SAMPLE MEASUREMENT	<0.000055	<0.000056	kg/day	*****	<0.049	<0.050	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.176			monthly	grab
4,4-DDT	SAMPLE MEASUREMENT	<0.0000105	<0.0000121	kg/day	*****	<0.097	<0.10	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.0000578	0.000146		*****	0.38	0.765			weekly	grab
PCB-1242	SAMPLE MEASUREMENT	<0.000031	<0.000036	kg/day	*****	<0.29	<0.30	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1248	SAMPLE MEASUREMENT	<0.000031	<0.000036	kg/day	*****	<0.29	<0.30	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1254	SAMPLE MEASUREMENT	<0.000031	<0.000036	kg/day	*****	<0.29	<0.30	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab

NAME/TITLE **PRINCIPAL EXECUTIVE OFFICER**
Glenn Grieb
Project Manager
 TYPED OR PRINTED

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)

Glenn Grieb
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE **732 572-4743**
 DATE **02 02 21**
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

**SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

FACILITY
LOCATION
ATTN:

**KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ**

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
02	01	01		02	01	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PCB-1260	SAMPLE MEASUREMENT	<0.000031	<0.000036	kg/day	*****	<0.29	<0.30	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
ARSENIC	SAMPLE MEASUREMENT	<0.00107	<0.00126	kg/day	*****	<10	<10	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.013	0.028		*****	85.0	172			weekly	comp
CADMIUM	SAMPLE MEASUREMENT	<0.00053	<0.00063	kg/day	*****	<5.0	<5.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp
CHROMIUM	SAMPLE MEASUREMENT	0.00112	0.00136	kg/day	*****	10.4	11.7	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.930	0.990		*****	198	396			weekly	comp
COPPER	SAMPLE MEASUREMENT	0.00031	0.00039	kg/day	*****	2.9	3.7	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
LEAD	SAMPLE MEASUREMENT	<0.00053	<0.00063	kg/day	*****	<5	<5	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
NICKEL	SAMPLE MEASUREMENT	<0.0043	<0.0050	kg/day	*****	<40	<40	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.140	0.291		*****	824	1850			weekly	comp
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)				TELEPHONE		DATE			
Glenn Grieb Project Manager						732 572-4743		02 02 21			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
						732		572-4743		02 02 21	

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

**SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT PERMIT NUMBER	001 DISCHARGE NUMBER
---------------------------------------	-------------------------

FACILITY
LOCATION
ATTN:

**KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
02	01	01		02	01	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNITS
ZINC	SAMPLE MEASUREMENT	0.0018	0.0026	kg/day	*****	21.0	25.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.177	0.356		*****	1170	2350			weekly	comp
CYANIDE	SAMPLE MEASUREMENT	<0.00107	<0.00126	kg/day	*****	<10.0	<10.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.002	0.004		*****	13.2	26.4			weekly	comp
ALUMINUM	SAMPLE MEASUREMENT	<0.0107	<0.0126	kg/day	*****	<100	<100	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	1.40	2.81		*****	3240	18300			weekly	comp
IRON	SAMPLE MEASUREMENT	<0.0107	<0.0126	kg/day	*****	<100	<100	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	88.6	162		*****	530000	1070000			weekly	comp
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT			***	*****	*****	*****	%	0		
	PERMIT REQUIREMENT	*****	*****		5(K)	*****	*****			see permit	equivalent
Ammonia	SAMPLE MEASUREMENT	*****	*****	***	*****	0.21	0.377	mg/l	0	*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	4.3	10.0			2/month	comp
	SAMPLE MEASUREMENT			***	*****	*****	*****			*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			*****	*****
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		02 02 21		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE NUMBER		YEAR MC DAY		
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									